

HERDS: 2020 School Lead in Drinking Water Reporting

© New York State Dept. of Health

Activity : 2020 School Lead in Drinking Water Reporting
 Organization : STOCKBRIDGE VALLEY CENTRAL SCHOOL
 Form : 2020 School Lead in Drinking Water Reporting
 Data Entity
 Type : Schools - Public
 Name : STOCKBRIDGE VALLEY CENTRAL SCHOOL
 Time Period :

Name : STOCKBRIDGE VALLEY CENTRAL SCHOOL (251501040001)
 Address 1 : 6011 WILLIAMS RD
 Address 2 :
 City : MUNNSVILLE
 State & Zip : NY-13409
 County : Madison (053)
 Region : Central Regional Office
 Phone & Fax: 315-495-4500 & -----

Section	Field	Value	Data Status	User	Updated
General Information	1. I understand that the information I am reporting is for the lead testing in school drinking water program for the 2020 compliance period.*	[Yes]	submitted	ms634418	11/16/2020 12:47 PM
	2. Was the school building you are reporting for constructed after January 4, 2014 or has a New York State Professional Engineer or Architect certified that the internal plumbing of the building is lead-free?	[Yes (Entire Building)]	submitted	ms634418	11/16/2020 12:47 PM
	3. Enter the website address where your school water lead results are posted.  	www.stockbridgevalley.org		ms634418	
Sampling Information	4. How many total outlets have been identified by the school that require sampling? 	72	submitted	ms634418	11/16/2020 12:47 PM
	5. Have all outlets been sampled, and samples submitted to an ELAP-approved laboratory for analysis?	[Yes]	submitted	ms634418	11/16/2020 12:47 PM
	6. Enter the date all initial sampling was completed for this compliance period:	10/06/2020	submitted	ms634418	11/16/2020 12:47 PM
	7. Enter the total number of outlets with a lead result	72	submitted	ms634418	11/16/2020 12:47 PM

HERDS: 2020 School Lead in Drinking Water Reporting

	less than or equal to the action level (15 ppb):				
	8. Enter the total number of outlets with a lead result greater than the action level (15 ppb):	0	submitted	ms634418	11/16/2020 12:47 PM
	9. Has your school received laboratory reports for all initial samples collected for this compliance period?	[Yes]	submitted	ms634418	11/16/2020 12:47 PM
	10. Enter the date all laboratory reports were received for the initial samples collected for this compliance period:	11/05/2020	submitted	ms634418	11/16/2020 12:47 PM
	11. Have the outlets with lead results greater than the action level (15 ppb) been taken out of service, remediated, or are appropriate controls in place to ensure water is not used for drinking or cooking?	[N/A]	submitted	ms634418	11/16/2020 12:47 PM
	12. Identify the status of remediation. (Examples of remediation include but are not limited to: permanent removal of outlets; replacing outlets and/or plumbing; or employing other engineering controls.)	[N/A]	submitted	ms634418	11/16/2020 12:47 PM
	By clicking the "Submit" button, I attest that all the data entered above is true and correct to the best of my knowledge, that I understand that such information shall be used for assessing regulatory compliance, and that I am authorized to				

HERDS: 2020 School Lead in Drinking Water Reporting

© New York State Dept. of Health

	submit this data on behalf of the school district or BOCES.				
--	---	--	--	--	--

**Required Fields. ** Repeatable Sections.*

Form Rules: